

List of CCN controllers supported in the CCN Auto Discovery SAL

If the Major Version of your equipment/controller is higher than what is shown in the list below yet it still does auto-instantiate, we strongly recommend that the resulting View and the Network Points list be inspected to insure that all points are properly mapped. Should any of the points not be mapped properly (they will be RED in the Network Points list, and their associated View objects may not appear properly), then the Equipment may need to be edited using SNAP and ViewBuilder.

If the equipment/controller version that you have is not on the list then it will be necessary to use SNAP and View Builder to create your own representation for that equipment. Refer to the I&S doc for SNAP, I-Vu 6.0 and View Builder for further information.

| | <u>Controller</u> | <u>Description</u> | <u>PIC Type</u> | <u>Major Version</u> | <u>CCN Auto Discovery SAL version</u> | <u>Notes</u> |
|-----------------|----------------------------|--|-----------------|----------------------|---------------------------------------|--------------|
| Zoning | 3V Zone Controller | Zone Controller | 044ZC | 1 | 20150128 | |
| | 3V Bypass Controller | Bypass Controller | 044BC | 1 | 20150128 | |
| | Comfort ID VAV | Single/Dual Duct, Fan | 035-- | 1+ | 20150128 | |
| | Monitor Stat | VVT Rooftop Controller/Zone | 033VM | 1 | 20150128 | |
| | PI Zone Controller | VVT PI Zone Controller | 033PI | 1 | 20150128 | |
| | PD Zone Controller | VVT PD Zone Controller | 033ZC | 1 | 20150128 | |
| | Bypass Controller | VVT Bypass Controller | 033BC | 1 | 20150128 | |
| | Monitor Stat | VVT Rooftop Controller/Zone | 1VM | 1 | 20150128 | |
| | PD Zone Controller | VVT PD Zone Controller | 1ZC | 1 | 20150128 | |
| | Bypass Controller | VVT Bypass Controller | 1BP | 1 | 20150128 | |
| | Underfloor Controller | Underfloor Fan Powered | 45UF | 2 | 20150128 | |
| | Air Sources | Fan Coil Controller | Fan Coil | 040ZC | 2 | 20150128 |
| 40UV/UH | | Unit Ventilation | 040UV | 2 | 20150128 | |
| AirManager | | Air Handler | 039LT | 1 | 20150128 | |
| Vertical Pack | | CC application | 64CC | | 20150128 | |
| Rooftops | 48/50A | 20-60 Ton Rooftop | 125AK | 2 - 5 | 20150128 | |
| | 48/50A | 20-60 Ton Rooftop | 125AK | 5 - 10+ | 20150128 | |
| | 48/50Z | 30-105 Ton Rooftop | 125CF | 3 | 20150128 | |
| | 48/50HG | Centurion | 050HG | 4 - 7 | 20150128 | |
| | 48/50PG | Puron Centurion | 050HH | 1-3 | 20150128 | |
| | 48/50PD | Puron Centurion | 050HH | 4 | 20150128 | |
| | 48/50PG | Puron Centurion | 050HH | 5 | 20150128 | |
| | 48/50 P Series | Puron Centurion | 125CP-1 | 5 | 20150128 | |
| | PremierLINK | Rooftops and WSHPs | 040RC | 1 | 20150128 | |
| | PremierLINK | Rooftops and WSHPs | 040RC | 2 | 20150128 | |
| | PremierLINK | Rooftops and WSHPs | 040RC | 3 | 20150128 | |
| | 48/50E | 48/50E pkg RTU & HP unit | 048EJ | 3 | 20150128 | |
| | Temp Stat | VVT Rooftop Controller | 033TM | 1 | 20150128 | |
| | Temp Stat | VVT Rooftop Controller | 1TM | 1 | 20150128 | |
| | 48NP 20-80 ton RTU | Package RTU (large) | 048NP | 2 | 20150128 | |
| | 48MP | 48MP 60-120 ton controller | 048MP | 1 | 20150128 | |
| | 50AZ/UZ | ProDialog for rooftop | 50AZ | 0 | 20150128 | |
| | 50HC-1 | Sm Puron RTU (04 - 06) | 50HC-1 | 1+ | 20150128 | |
| | 50LC-1 | Med Puron RTU (4 - 60) | 50LC-1 | 1+ | 20150128 | |
| | 48/50N | Puron Centurion | 129CN | 1+ | 20160428 | |
| Chillers | 19XR/XRV (CVC/ICVC) | Hermetic Centrifugal Chiller | 019RR | 7 | 20150413 | 1 |
| | 23XL Pic II | Hermetic Screw Chiller | 023LL | 2 | 20150413 | 1 |
| | 23XL Pic I | Hermetic Screw Chiller | 23XL | 3 | 20150413 | 1 |
| | 30RA | AquaSnap Scroll Chiller NAO | 030RA | 1 - 4 | 20150413 | 1 |
| | 30RB | AquaSnap Scroll Chiller NAO (Dual ver RA-4) | 030RB | 1 - 4 | 20150413 | 1 |
| | 30RAP - Version 5.0. | AquaSnap Scroll Chiller NAO | 030SA | 5 | 20150413 | 1 |
| | 30RAP - Version 5.0. | AquaSnap Scroll Chiller NAO (Dual ver RAP-5) | 030SB | 5 | 20150413 | 1 |
| | 30RAP - Version 2.05. | AquaSnap Scroll Chiller NAO | 030SA | 2 | 20150413 | 1 |
| | 30RAP - Version 2.05. | AquaSnap Scroll Chiller NAO (Dual ver RAP-2) | 030SB | 2 | 20150413 | 1 |
| | 30RAP - Version 4 | AquaSnap Scroll Chiller NAO | 030RX | 4+ | 20160613 | 1 |
| | 30RAP - Version 4 | AquaSnap Scroll Chiller NAO (Dual ver RAP-4) | 030RY | 4+ | 20160613 | 1 |
| | 30GX ComfortLink | Screw Chiller | 030CS | 3 | 20150413 | 1 |
| | 23XR Foxfire (CVC/ICVC) | Screw Chiller | 023XR | 1 | 20150413 | 1 |
| | 23XR-A2 Foxfire (CVC/ICVC) | Screw Chiller | 023RR | 1+ | 20170808 | 1 |
| | 30GTN Series | Dual Circuit Recip Chillers | 030GM | 2 | 20150413 | 1 |

List of CCN controllers supported in the CCN Auto Discovery SAL

| | | | | | | |
|--------------------|------------------------------------|--|-------|-----|-----------------|----------|
| | 32XR (CVC/ICVC) | Centrifugal Chiller High Pressure Retrofit | 19HP | 1 | 20150413 | 1 |
| | 32DK (CVC/ICVC) | Centrifugal Chiller Low Pressure Retrofit | 19LP | 1 | 20150413 | 1 |
| | CSM Interface | Generic Chiller Interface | 030CI | 1 | 20150413 | 1 |
| | 19XR/XRV/XD - PIC 5 Touch Pilot | Hermetic Centrifugal Chiller | 19XR | 4+ | 20180509 | 1 |
| | 19XR/XRV - PIC 5 Touch Pilot | Hermetic Centrifugal Chiller | 19XR | 3+ | 20170808 | 2 |
| | 19XR/XRV (CVC/ICVC) | Hermetic Centrifugal Chiller | 19XV | 2 | 20150413 | 1 |
| | 19XD/XD (CVC/ICVC) | Hermetic Centrifugal dual Chiller | 19XD | 2 | 20150413 | 1 |
| | 30GX/HXC | Enhanced Screw Chiller | 30CT | 2+ | 20150413 | 1 |
| | 16JB | Absorption Chiller | 16JB | 5 | 20150413 | 1 |
| | Prodialog Plus 30GX/HX | (EMEA)Global Screw Chiller | 030PX | 6 | 20150413 | 1 |
| | Prodialog 30RA/RH | Aquasnap Chiller | 030RA | 5 | 20150413 | 1 |
| | Prodialog Plus 30RB/RQ Puron | Starfire | 030ST | 2-4 | 20150413 | 1 |
| | Prodialog Plus 30RB/RQ Puron | Starfire | 030ST | 5+ | 20150413 | 1 |
| | Prodialog Plus 30RW | AquaSnap Water Cooled Chiller | 030RW | 3 | 20150413 | 1 |
| | Prodialog Plus 30GK/HZ | (EMEA) Air Cooled Recip Chiller | 030PK | 2 | 20150413 | 1 |
| | AquaForce 30XA | Screw chiller | 030TH | 2 | 20150413 | 1 |
| | Mini-chiller | (EMEA)ProDialog for chiller | 030EX | 0 | 20150413 | 1 |
| | 38AP Split Controller | | 038AP | 5 | 20150413 | 1 |
| | 30MP Aquasnap Chiller | | 030MP | 2 | 20160428 | 1 |
| | AquaForce 30XV - Touch Pilot | AquaForce Air-Cooled Screw Chiller | 030XF | 1 | 20170808 | 1 |
| | AquaForce 30XWV - Touch Pilot | AquaForce Air-Cooled Screw Chiller | 030XD | 1+ | 20170808 | 1 |
| | AquaForce 30XAV - Touch Pilot | AquaForce Air-Cooled Screw Chiller | 030XF | 3 | 20170808 | 1 |
| System Mgrs | Chillervisor Sys Manager III (CSM) | Chiller Manager | 046CP | 5 | 20150128 | |
| | Flotronic System Manager (FSM) | Chiller Manager | 105FS | 1 | 20150128 | |
| | Terminal System Manager | TSM 2 and TSM 2 Plus | 100TS | 3 | 20150128 | |
| Generic | Comfort Controller | | 064CC | 1 | 20150128 | |
| | Universal Controller | | 125UX | 1 | 20150128 | |
| | Generic Controller | | | | 20150128 | |
| | Serial Bridge | | 100BR | 3 | 20150128 | |
| | Ethernet Bridge | | 100EN | 1 | 20150128 | |
| | System Pilot | | 44SS | 1 | 20150128 | |
| | I-Vu integrator | | 146AL | 2 | 20150128 | |
| | TeLink | | 110PC | 1 | 20150128 | |
| | DCIV | | 100ED | 1 | 20150128 | |
| | i-Vu Link | | 100LK | 2 | 20150128 | |
| | i-Vu Router | | 100RT | 2 | 20150128 | |
| | i-Vu Internal Gateway | | 100ST | 2 | 20150128 | |

Note 1 Support ChillerVU™ "Plug & Play" Integration

Note 2 Touch Pilot software version SCG-SR-20M200330 does not support CCN alarming and ChillerVU™ "Plug & Play" Integration.

Revised:05/16/2018